

Chariton Valley Biomass Project

Research / Reports



Crop Studies & Cost



Soil Stability/Erosion/Carbon



Harvest Impacts on Wildlife



Air/Ash/Water Impacts

Equipment Development



Baler Development



Bale Accumulator



Bale Handling



Biomass Processing

Processing Facility



June 2005



August 2005



September 2005



November 2005


Outreach



Public Outreach




Web Outreach



Publications

Switchgrass Cofiring Ottumwa, Iowa

- Ottumwa Generating Station
 - Alliant Energy / Mid-American
 - 726 MW, PRB Coal, 1982 startup
 - Twin furnace T-fired PC boiler
 - 2.5 to 5% heat input from switchgrass, 12.5 to 25 ton/hr
 - Separate biomass injection, 2 - 4 ports
- Status
 - 2000 hr continuous test burn on-going
 - Newly constructed facility completed
 - Long term test to investigate fouling, slagging, and corrosion impacts
- Fuel
 - 3' x 4' x 8' switchgrass bales
 - 2-step milling process to 1/8" minus




Project Characteristics


- Test Facility (The “Grass Station”)
 - Designed for 12.5 ton/hour
 - 25,000 tons of switchgrass for 2,000 hour continuous test burn accumulated from 4,000 acres over several years
 - Contains several innovative, first-of-a-kind pieces of equipment (which are working great)
 - 17.5 MW of **BASELOAD** Renewable Energy
 - Automated control & monitoring system
 - 24 hour data logging
 - Would require 100,000 tons/yr, from 25k to 75k acres initially
- Commercial Facility
 - Designed for 25 tons/hr
 - Designed for automated crane operation based on Danish straw-fired plants
 - 35.0 MW of **BASELOAD** Renewable Energy
 - Air permits already granted for construction on the merit of previous air emissions test results
 - Would require 200,000 tons/yr, from 50k to 150k acres initially

SWITCHGRASS


- DECREASED WINDFLOW AND EVAPORATION



- LESS EROSION FROM SURFACE FLOW



- DEEP ROOTING SYSTEM BENEFITS



- NATIVE C4 PERENNIAL

- CAN BE GROWN ON MARGINAL LANDS OR ROTATED WITH OTHER CROPS

- EXCELLENT NESTING AND INVERTEBRATE HABITAT

- ROOT MASS CAN REACH 8 DRY Mg/ha; AN EXCELLENT CARBON SINK





Growing Season



After Frost, Before Harvest



During Harvest



After Harvest






Replacing up to 5% of this . . .



with this . . .







Switchgrass Blow Lines Transporting Ground Switchgrass into Boiler House (left) and Boiler (right).

New Biomass Process Facility

Ottumwa Generating Station





7:56:14

3/6/06

BALE DATA SCREEN

TOTAL BALE COUNT

4361

DAILY
BALE COUNT

141

RESET

TOTAL WEIGHT

2154

(TONS)

DAILY WEIGHT

69

(TONS)

RESET

TOTAL HOURS

262.7

DAILY HOURS

7.3

RESET

BL-1 TOTAL
BURN HOURS

220.4

BL-1 DAILY
BURN HOURS

6

RESET

BL-2 TOTAL
BURN HOURS

221.8

BL-2 DAILY
BURN HOURS

6

RESET

SYSTEM
FEED RATE

0.0

FT PER
MIN.SYSTEM
FEED RATE

0.0

TONS PER
HOURBALE MOISTURE
0-100%

CONT. 0

AVG. 11

OPERATOR INPUT FIELD

LOAD INFORMATION

CURRENT LOAD
BALE COUNT

22

PREVIOUS LOAD
BALE COUNT

45

CURRENT
LOAD WEIGHT

0

(TONS)

PREVIOUS
LOAD WEIGHT

0

(TONS)

OPERATOR SETPOINTS

BALES PER LOAD

45

SETPOINT

TRUCK NUMBER LOAD NUMBER

98

76

START BALE COUNT

START

PAUSE

RESET

TRENDING SCREEN

FAULT MESSAGES

SYSTEM SETPOINTS

SPEED SENSORS

MAIN OVERVIEW

MAINTENANCE MODE

Summary Statistics to Date

Summary Statistics:

Date :	Wednesday, March 22, 2006
Bale Count :	529 bales
Run Time :	24.0 hrs
Total Bale Weight :	247.9 tons
Max. Bale Weight :	1,353 lbs.
Min. Bale Weight :	743 lbs.
Average Bale Weight:	937 lbs.
Average Moisture Content:	13%

Overall Statistics (through midnight):

Total Bales Processed (accepted) :	11,264 bales
Total Tons Processed (accepted) :	5,567
Average Bale Weight:	988 lbs./bale
Total System Processing Hours:	627.6 hours
Percent of Run-hour Goal:	31% of 2000 hour goal
Percent of Tonnage Goal:	22% of 25,000 ton goal
Estimated Power Generated :	6,975 MWh
Time Remaining until May 12th Outage:	50 days
	1,200 hours


Average Iowa Homes Powered for Full Year : 667 average annual homes

TRENDING SCREEN #1

BALE_MOISTURE	20
BALE_EJECT_CYCLE	0
REJECT_BALE_MOISTURE	20
	0

Bale Moisture Content and Eject Cycles Monday, February 20, 2006


5:35:16 AM



BALE_WEIGHT	1500
	500

Bale Weight Monday, February 20, 2006

5:35:18 AM



TRENDING SCREEN 2

TRENDING SCREEN 3

FAULT MESSAGES

SYSTEM SETPOINTS

SPEED SENSORS

MAIN OVERVIEW

MAINTENANCE MODE

8:38:14



3/1/06


TRENDING SCREEN #2

Feed Rate (Feet Per Min)



Wednesday, March 01, 2006

8:38:22 AM

	C-710_FEET_PER_MIN	15
	C-710_TONS_PER_HOUR	15




	0
	0

	BL1_SOUND_SW_IND	2
	BL2_SOUND_SW_IND	2

Sound Sensors

Wednesday, March 01, 2006

8:38:30 AM



	0
	0

TRENDING SCREEN 1

TRENDING SCREEN 3

FAULT MESSAGES

SYSTEM SETPOINTS

SPEED SENSORS

MAIN OVERVIEW

MAINTENANCE MODE

8:29:08

3/1/06


TRENDING SCREEN #3

DEBALER MOTOR AMPS

Wednesday, March 01, 2006

8:29:29 AM

DB1A_MOTOR_AMPS	500
DB1B_MOTOR_AMPS	500
HM1A_MOTOR_AMPS	500
HM1B_MOTOR_AMPS	500



61
61
107
106

TRENDING SCREEN 1

TRENDING SCREEN 2

FAULT MESSAGES

SYSTEM SETPOINTS


SPEED SENSORS

MAIN OVERVIEW

MAINTENANCE MODE

CHARITON VALLEY BIOMASS PROJECT

Daily Switchgrass Processing Chart (Friday March 10, 2006)



Biopower Calculation

- Measure tons per hour and Btu biomass input in real-time using:
 - Digital scale on conveyor system
 - Microwave moisture content meter
 - Lab analysis of switchgrass samples (Btu/lb)
- Calculation
 - $$\text{MW} = \frac{(12.5 \text{ ton/hr})(2000 \text{ lb/ton})(6980 \text{ Btu/lb})}{(11,000 \text{ Btu/kw-hr})(1000 \text{ kW/MW})}$$

FERC Form 1 OGS Heat Rate
 - MW = 15.86 MW
- We also **measure** reduction in coal flow as biomass flow increases

Emissions Monitoring (GE)

*Emissions Probe
In Outlet Duct*



*GE's Mobile
Emissions Lab*



*GE's Emissions
Vans at Stack*



CO, NO_x, O₂, PM, PM₁₀, Hg, Cl

Emissions Equipment at OGS

CEMS Probes In Outlet Duct



SO₂, NO_x, Opacity

Portable Emissions Monitor



CO, SO₂, NO_x, O₂

Other Sampling



Bottom Ash Liquids

Economizer Ash

Fly Ash Auto Sampler




*Bottom
Ash*

*Bulk
Fly
Ash*




Chariton Valley Biomass Project--Interim Test Burn NOx & SO2 vs. Cofire Rate, Ottumwa Generating Station

Continuous Emissions Monitoring System Data for: December 1 to 5, December 8 to 12, 8 am to 6 pm



Hourly Average SO₂ Readings



Summary: Emissions Results (Interim Test Burn)

- From Continuous Emissions Monitoring System:
 - 6000 minutes of emissions data collected and analyzed
 - 8 am – 6 pm on all test days
 - 53 hours cofiring, 47 hours coal-only
 - Average heat input from switchgrass was 1.9% of boiler total
 - **Results when cofiring:**
 - Average Sulfur Dioxide (SO₂) emissions decreased by over 4%
 - Average Nitrogen Oxides (NO_x) emissions did not change
- From Stack Emissions Testing:
 - Particulates decreased by 4% (PM), and 14% (PM₁₀)
 - Carbon Monoxide (CO) emissions did not change

Conceptual drawing of a 25 ton/hr automated system based on operating Danish straw plants

